



Intertek

Intertek Testing & Certification Limited

Intertek House, Cleeve Road, Leatherhead, Surrey, KT22 7SB. United Kingdom.

Phone: +44 (0)1372 370900

Fax: +44 (0)1372 370999

E-mail: cpd.uk@intertek.com

Web: www.intertek.com

Intertek Scheme Number: **ITS-09/01**

Certificate Number: **ITS-09/0140**

Certificate of Conformity

This certificate shows that the bearer has successfully completed the requirements of ITS-09/01.

The company has been registered within the ITS-09/01 scheme for the products detailed in the accompanying schedule.

Intertek Warnock Hersey Mark for fire resisting doors and hardware

Certificate Holder: ZHEJIANG JIAHUI DOORS CO., LTD.
Address: No.6, Jiahui Road, Gumashan Industrial Zone, Wangzhai Town, Wuyi City, Zhejiang Province, 321200, CHINA.
 T: +86 579 8909 6886 F: +86 579 8909 6885
 E: admin@jiahuidoor.com.cn W: www.jiahuidoor.com.cn



010

Product: "Double Leaves Swing Steel Fire Door Assembly"
Type: Steel fire door and frame
Product description: Single action, double door (SADD)
Ratings and principal characteristics: 120 minutes Integrity & 30 minutes Insulation
Test standard(s): BS 476-22:1987
Schedule: 140829012SHJ-BP-1

Date of First Issue: 02 Apr 2015
Revision number: -
Revision date: -
Valid Until: 02 Apr 2020

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

David Bigland Certification Manager – Building Products		02 Apr 2015
Name/Position	Signature	Date